Thank You

Thanks for purchasing a MPI series magnetostrictive level sensor from us! We appreciate your business and your trust. Please take a moment to familiarize yourself with the product and this manual before installation. If you have any questions, at any time, don't hesitate to call us at 888-525-7300.

You can also find a full list of our product manuals at: www.apgsensors.com/resources-user-manuals/

MPI-F Magnetostrictive Level Sensors

For Intrinsically Safe, Flexible SS and PVDF Stem Probes

Installation Guide

Table of Contents

- 1. Description
- 2. How To Read Your Label
- 3. Warranty
- Shipping Box Contents
 Installation Guidelines
- 6. Dimensions
- 7. PVDF Installation
- Temperature Requirements

Instructions 9. Electrical Installation Instructions

13. Hazardous Location

Installation Drawings

10. Sensor and System Wiring

8. Physical Installation

- Diagrams
- **11.** General Care
- **12.** Repair Information

1 Description

The MPI-F series magnetostrictive level sensor provides highly accurate and repeatable level readings in a wide variety of liquid level measurement applications. It is certified for installation in Class I, Division I, and Class I, Zone O hazardous areas in the US and Canada by CSA, and ATEX and IECEX for Europe and the rest of the world. The MPI-F's flexible stem allows for installation in tanks up to 50 feet tall, without needing a crane or an extralong truck and trailer for delivery. APG's proprietary-PVDF-formulation stem provides increased flexibility and impact resistance during cold-weather installation, along with compatibility in a wider range of corrosive media—including H2S—in larger tanks.

2 How To Read Your Label

Each label comes with a full model number, a part number, and a serial number. The model number for the MPI will look something like this:

SAMPLE: MPI-F8-KH-P2SK-120-4D-N2NW6

The model number correlates with all the configurable options and tells you exactly what you have. Compare the model number to the options on the datasheet to identify your exact configuration. You can also call us with the model, part, or the serial number and we can help you.

You'll also find all hazardous certification information on the label.

8 Warranty

This product is covered by APG's warranty to be free from defects in material and workmanship under normal use and service of the product for 24 months. For a full explanation of our Warranty, please visit <u>www.apgsensors.com/resources/warranty-certifications/warranty-returns/</u>. Contact Technical Support to receive a Return Material Authorization before shipping your product back.



Automation Products Group, Inc.Part # 2003401025 W 1700 N Logan, UT 84321Doc #9005626www.apgsensors.com | phone: 888-525-7300 | email: sales@apgsensors.comRev D1, 11/2024


Installation Guidelines

The MPI-F should be installed in an area—indoors or outdoors—which meets the following conditions:

- Ambient temperature between -40°F and 185°F (-40°C to 85°C)
- Relative humidity up to 100%
- Altitude up to 2000 meters (6560 feet)
- IEC-664-1 Conductive Pollution Degree 1 or 2
- IEC 61010-1 Measurement Category II
- No chemical corrosive to stainless steel (such as NH3, SO2, Cl2, etc.). (Not applicable to plastictype stem options)
- Ample space for maintenance and inspection

Additional care must be taken to ensure:


- The probe is located away from strong magnetic fields, such as those produced by motors, transformers, solenoid valves, etc.
- The medium is free from metallic substances and other foreign matter.
- The probe is not exposed to excessive vibration.
- The float(s) fit through the mounting hole. If the float(s) does/do not fit, it/they must be mounted on the stem from inside the vessel being monitored.
- The float(s) is/are oriented properly on the stem (See Figure 5.1 below). MPI-F floats are installed by customer.



IMPORTANT: Floats must be oriented properly on the stem, or sensor readings will be inaccurate and unreliable. Untapered floats will have a sticker or etching indicating the top of the float. Remove sticker prior to use.

Conditions of Use:


- 1. Under certain extreme circumstances, the non-metallic parts incorporated in the enclosure of this equipment may generate an ignition-capable level of electrostatic charge. Therefore the equipment shall not be installed in a location where the external conditions are conducive to the build-up of electrostatic charge on such surfaces. In addition, the equipment shall only be cleaned with a damp cloth.
- 2. The enclosure is manufactured from Aluminium. In rare cases, ignition sources due to impact and friction sparks could occur. This shall be considered during installation.
- 3. Model MPXI shall be installed as per drawing 9006113.
- 4. Unused entries of model MPXI shall be closed with blanking elements maintaining explosion



- proof properties and ingress protection rating of the enclosure.
- 5. For information on the dimensions of the flameproof joints the manufacturer shall be contacted.
- 6. For model MPXI only, the Stem Assembly shall not be subject to vibrations or exposed to chemicals which might adversely affect the partition wall.


③ IMPORTANT: Only the combustion gas detection performance of the instrument has been tested.

MPI-F/B (SS Stem) Dimensions with 2"Ø Weights




Probe Length in Inches	S1 Top Deadband Length	Number & To of 2"Ø Stem	Length of 1"Ø Tubing	
L ≤ 96″	6″	1	4.75″	8″
97″ ≤ L ≤ 144″	6"	2	9.5″	8″
145″ ≤ L ≤ 192″	8″	2	9.5″	8″
193″ ≤ L ≤ 300″	8″	3	14.25″	14″
301″ ≤ L	10"	3	14.25″	14″


MPI-F/B (SS Stem) Dimensions with 3"Ø Weights




Probe Length in Inches	S1 Top Deadband Length	Number & Total Height of 3"Ø Stem Weights			
L ≤ 144″	6″	1	3"		
145″ ≤ L ≤ 192″	8″	1	3″		
193″ ≤ L ≤ 300″	8″	2	6″		
301″ ≤ L	10"	2	6″		


MPI-F/K (PVDF Stem) Dimensions








Measurable Length = Total Length - S1 - S2 S1 = Top Deadband S2 = 1 Float Height + Weight(s) Height + 0.5"




Measurable Length = Total Length - S1 - S2 S1 = Top Deadband S2 = 1 Float Height + Weight(s) Height + 0.5"

Probe Length in Inches	S1 Top Deadband Length†	Number & Total Height of Stem Weights	
L ≤ 144″	6″	1	5″
145″ ≤ L ≤ 300″	8″	2	10″
301″ ≤ L ≤ 330″	10″	2	10″
331″ ≤ L ≤ 516″	10″	3	15″
517″ ≤ L	10″	4	20″

Measurable Length = Total Length - S1 - S2 S1 = Top Deadband S2 = 1 Float Height + Weight(s) Height + 0.8625"



4.17" [106.0 mm]




PVDF Installation Temperature Requirements

Prior to installing a PVDF-stem MPXI-F, the interior, mid-column temperature of the tank must be measured to determine the amount clearance needed at the bottom of the probe for thermal expansion. See Figure 7.1.

- Determine interior, mid-column temperature in °F. 1
- Determine interior tank height from top of probe mounting to tank interior bottom, in inches. 2.
- Use formula in Figure 7.1 to determine necessary clearance from bottom of probe to interior 3. tank bottom.
- If necessary, adjust placement of slide mount on probe to accommodate required clearance. 4.

Contact factory with any PVDF-stem thermal expansion requirement questions.



PROBE CLEARANCE = .000108 * (185 - INSTALL TEMPERATURE) * INTERNAL TANK HEIGHT

† TEMPERATURE IN DEG. F LENGTH IN INCHES

Figure 7.1

8 Physical Installation Instructions

Ensure that all components have been received, including:

- MPI-F sensor (head and stem, slide mount if purchased)
- Float or floats, if purchased from APG
- Stem Weight(s); Weight-Locking Pin and Set Screw for SS; Top Weight Retention Ring (with two screws), Dowel Pin for PVDF
- Assembly drawing

Assemble sensor mounting, float(s), weight and pins at installation location, if possible.

- If not already attached, slide mounting option onto stem. Loosen compression cap so it will slide easily on stem. For probes with PVDF stems, be sure to account for thermal expansion clearance (see section 7) when placing slide mount on stem.
- For SS sensors with float stops, refer to the assembly drawing included with the sensor for float stop installation locations. PVDF float stops are installed at the factory.
- Note: If the floats do not fit through the tank/vessel mounting hole, mount them on the stem from inside the vessel being monitored. Then secure the sensor to the vessel.
- Slide floats onto stem. If using two floats, slide the lighter float on first. Tops of floats will be indicated by sticker, taper, or etching on float. (See Figure 5.1) After ensuring top of float is toward MPI-F sensor head, remove sticker(s).
- PVDF stem

Electrical Installation Instructions

- Remove the housing cover of your MPI.
- Feed system wires into MPI through NPT conduit openings. Any fittings used must be UL/CSA Listed for CSA installation.
- Connect wires to MPI terminals. Use crimped ferrules on wires, if possible.
- Replace the housing cover.

See Sensor and System Wiring Diagrams (section 10) for wiring examples.

1 IMPORTANT: For EMI protection, either connect the ground screw (see section 6) to an earth ground, or ensure that tank mounting of the MPI-F is grounded.

- - Slide weight retention ring onto stem, then insert weight(s) on end of stem
 - Secure dowel pin in end of stem (use hammer/mallet if necessary)
 - Slide weight(s) down onto dowel pin
 - Lock weight(s) in place by sliding weight retention ring down to top weight, tighten ring
- For SS stem:
 - Insert weight(s) on end of stem
 - Insert weight-locking pin into end plug hole
 - Lock into place with set screw, using 1/8" allen wrench


Install MPI-F sensor on tank

- When lifting and installing the sensor be sure to minimize the bending angle between the rigid stem at the top and bottom of the sensor and the flexible stem in-between. Sharp bends at those points could damage the sensor. The 10" bend radius of the PVDF probe's shipping box can be used as a guide for the smallest allowable bend for the PVDF stem (see PVDF Shipping Box Contents, section 4).
- If your sensor's stem and float(s) fit through the mounting hole, insert the weight and the floats into the mount opening.
- Carefully unroll and feed the MPXI-F sensor stem into the tank, being careful to not let the float(s) drop uncontrolled on the stem. Slide the mount up to the top of the stem.
- For PVDF stem:
 - When the weight is on the bottom of the tank, secure the mounting option to the vessel.
 - Take any slack out of the flexible stem, raising bottom of stem to previously calculated clearance height (see section 7).
 - Tighten the compression fitting to hold stem in place.
- For SS stem:
 - When the weight is on the bottom of the tank, secure the mounting option to the vessel.
 - Take any slack out of the flexible stem.
 - Tighten the compression fitting to hold stem in place.

NOTE: Damage due to floats dropped on stem may not be covered by warranty.

Sensor and System Wiring Diagrams

MPI-F Modbus System Wiring



MPI-F Modbus System Wiring with RST-6001

correctly. However, in general, you should periodically inspect your MPI unit to ensure the stem is free of any heavy buildup that might impede the movement of the float(s). If sediment or other foreign matter becomes trapped between the stem and float(s), detection errors can occur.

If you need to remove the float(s) from the stem of your MPI, be sure to note the orientation of the float(s) prior to removal. This will help ensure proper re-installation of the float(s).

Also, ensure that the housing cover is secured snugly. If the cover becomes damaged or is misplaced, order a replacement immediately.

1 IMPORTANT: All repairs and adjustments of the MPI-F level sensor must be made by the factory. Modifying, disassembling, or altering the MPI-F is strictly prohibited.

12 Repair Information

If your MPI-F level sensor needs repair, contact us via email, phone, or online chat on our website. We will issue you an RMA number with instructions.

- Phone: 888-525-7300
- Email: sales@apgsensors.com
- Online chat at www.apgsensors.com

DANGER: OPEN CIRCUIT BEFORE REMOVING COVER or KEEP COVER TIGHT WHILE CIRCUITS ARE ALIVE; AVERTISSEMENT -- COUPER LE COURANT AVANT D'ENLEVER LE COUVERCLE, ou GARDER LE COUVERCLE FERME TANT QUE LES CIRCUITS SONT SOUS TENSION.

DANGER: WARNING -- EXPLOSION HAZARD -- SUBSTITUTION OF COMPONENTS MAY IMPAIR INTRINSIC SAFETY; AVERTISSEMENT -- RISQUE D'EXPLOSION -- LA SUBSTITION DE COMPOSANT PEUT AMELIORER LA SECURITE INTRINSIQUE.

DANGER: WARNING -- EXPLOSION HAZARD -- DO NOT DISCONNECT EQUIPMENT UNLESS POWER HAS BEEN SWITCHED OFF OR THE AREA IS KNOWN TO BE NON-HAZARDOUS: AVERTISSEMENT -- RISQUE D'EXPLOSION -- AVANT DE DECONNECTER L'EQUIPEMENT, COUPER LE COURANT OU S'ASSURER QUE L'EMPLACEMENT EST DESIGNE NON DANGEREUX.

	AUTOMATION PRODUCTS GROUP, INC.			Au	tomation Products G	roup, Inc.	888.525.7300	
	LOGAN, UTAH AND MAY NOT BE	CHKD S. Hutchins	8/29/2018			000.323.7300		
	USED, REPRODUCED, PUBLISHED, OR DISCLOSED TO OTHERS WITHOUT		8/29/2018	MPI Series				
WRITTEN CONSENT OF THE COMPANY. IF LOANED, IT IS SUBJECT TO RETURN UPON DEMAND AND MAY NOT BE USED			 Intrinsically Safe Installation Drawing for Hazardous Locations 					
	CONTRACT					REV		
	IN ANY WAY DIRECTLY OR INDIRECTLY DETRIMENTAL TO THE COMPANY			A 52797 VARIOUS 9005491			B	
		FINISH					SHEET 1 OF	2

DATE

6/5/2018

ordance with NEC Articles 504 and 505.

APG

1025 West 1700 Nort

Logan, Utah USA

must be in acc

APPROVALS

C. Chidester

AGENCY APPROVED DRAWING

PROPRIETARY AND CONFIDENTIAL

THIS DRAWING IS THE PROPERTY OF

		REVISIO	ONS		
ZONE	REV	DESCRIPTION	CHANGE ORDER	DATE	APPROVED
	в	See Change Order	CO-3982	06/01/2020	A. Fullmer

